

# NEMA Motor Round Robin


Pierre Angers

Hydro-Quebec Research Institute

November 14<sup>th</sup> 2018

Motor Summit 2018 International

Zurich, Switzerland



Innovation, équipement  
et services partagés

# Context

---

- National Electrical Manufacturers Association (NEMA) Motor and Generator Section
- Round Robin Testing Program
- NEMA Premium<sup>®</sup> Efficiency Motor Rated 5 hp (3,7 kW), 4-pole
- Perform Testing on the Same Motor by Different Participating Accredited Independent Laboratories (4) and Motor Manufacturers (7)
- Different Set-up, Instrumentation and Technical Staff

# Context

---

- Agreement Not to Disclose Name of Participants
- Compare Results Based on the Same Testing Procedure IEEE 112-2004 Method B (Equivalent to IEC 60034-2-1 or CSA C390)

# Approach

---

- Same NEMA Premium<sup>®</sup> Efficiency Motor Rated 5 hp (3,7 kW), 4-pole
- Thermocouples Installed in the Motor Prior to the First Test
- Use of the Same Calculations Template
- First Test and Last Test Performed by the Same Participant for Repeatability Assessment
- Seals Applied Against Tampering
- "True" Efficiency not Known
- "Average" Efficiency as Reference for Comparison

# Steps for Efficiency (or Losses) Determination

---

- Cold Resistance Measurement
- Temperature Test or Heat Run
- Hot Resistance Measurement
- Load Points Measurements



Load Losses:  
Stator, Rotor, Additional


- No-Load Measurements



Constant Losses:  
Iron, Windage / Friction

- Calculations → Efficiency (or Losses) Determination

# Test Set-up – Power Supply - Voltage




\* CSA 390

# Test Set-up – Power Supply - Frequency

	Power Supply Frequency (Hz)					
	% Nominal Load					
	25%	50%	75%	100%	115-125%	125-150%
Lab-1	60	60	60	60	60	60
Lab-2	59.99	60.00	60.00	60.00	60.01	59.99
Lab-3	60.00	59.99	60.01	60.02	60.00	59.99
Lab-4	60.02	60.02	60.02	60.02	60.02	60.02
Man-A	59.97	60.02	60.01	60.03	59.99	59.98
Man-B	60.04	60.02	59.99	60.01	60.03	60.01
Man-C	60	60	60	60	60	60
Man-D	59.97	59.99	59.99	60.00	59.99	60.01
Man-E	60	60	60	60	60	60
Man-F	60	60	60	60	60	60
Man-G	60	60	60	60	60	60
Man-H	60	60	60	60	60	60

# Test Set-up – Power Supply - Frequency


## Frequency Variations from Nominal






# Resistance Measurements

---




# Constant Losses: Iron Loss – Windage / Friction Loss


**Iron Loss  
(Constant Loss)**





**Windage / Friction Loss  
(Constant Loss)**



**Impact on Efficiency of Iron + W/F Losses  
(From Average at Nominal Load)**




# Stator Loss




# Rotor Loss

### Rotor Winding Loss (Difference in Watts From Average)




### Impact on Efficiency of Rotor Winding Loss (From Average at Nominal Load)




# Additional Loss


**Additional Loss  
(Difference in Watts From Average)**




**Impact on Efficiency of Additional Loss  
(From Average at Nominal Load)**



# All Losses



# Impact of Additional Loss




# Additional Loss → Linear Regression Analysis

---

- Torque Measurement → Residual Loss → Additional Loss
- Additional Loss Not directly Measured but Computed
- Standard Requirement: Correlation Coefficient  $\geq 0.90$
- No Requirement for Intercept
- All Labs except One had Correlation Coefficient  $\approx 0.99$
- But some of Them had Large Value of Intercept
- Large Intercept → No Reconciliation
- Difference in Torque Transducer Calibration?




# Additional Loss → Linear Regression Analysis



# Nominal Efficiency


Max Deviation :  $\pm 0.4$  Percentage Point



# NEMA Efficiency Levels


---

NEMA Premium 5 hp  
4-pole (3.7 kW)



- 90.2 %
- 89.5 %
- 88.5 %

# Impact on Efficiency vs Load



# Conclusions

---

- 11 Participants Testing the Same 5 hp (3.7 kW), 4-pole Motor
- $\pm 0.4$  Percentage Point over Average Efficiency of 89.6 %
- Maximum Variability Between Participants  $\rightarrow$  Additional Loss
- All Labs except One had Correlation Coefficient  $\approx 0.99$
- Intercept Not Necessarily Considered (but Should)
- Torque Measurement and Calibration
- To Achieve Best Result  $\rightarrow$  CC Near 1.00 and an INT Toward 0.00
- Difficult to Meet Such Requirements for Larger Motors



**Pierre Angers, Eng.**

Hydro-Quebec Research Institute

600 Ave. de la Montagne, Shawinigan, Quebec, Canada

[angers.pierre@ireq.ca](mailto:angers.pierre@ireq.ca)